

# User's guide

SMRI2 SMRI5





- Magnetic modular encoder with incremental output
- For 2-mm (SMRI2) or 5-mm (SMRI5) pole pitch rings
- Resolutions up to 180,000 PPR
- Ring diameters for shafts up to 250 mm
- IP67 (standard) / IP69K protection rate
- Cable or M12 connector output

Table of Contents	
Preliminary information	5
1 – Safety summary	6
2 - Identification	8
3 - Mechanical installation	9
4 - Electrical connection	16
5 - Maintenance and troubleshooting	24
	Preliminary information 1 – Safety summary 2 – Identification 3 – Mechanical installation 4 – Electrical connection

This publication was produced by Lika Electronic s.r.l. 2019. All rights reserved. Tutti i diritti riservati. Alle Rechte vorbehalten. Todos los derechos reservados. Tous droits réservés.

This document and information contained herein are the property of Lika Electronic s.r.l. and shall not be reproduced in whole or in part without prior written approval of Lika Electronic s.r.l. Translation, reproduction and total or partial modification (photostat copies, film and microfilm included and any other means) are forbidden without written authorisation of Lika Electronic s.r.l.

The information herein is subject to change without notice and should not be construed as a commitment by Lika Electronic s.r.l. Lika Electronic s.r.l. reserves the right to make all modifications at any moments and without forewarning.

This manual is periodically reviewed and revised. As required we suggest checking if a new or updated edition of this document is available at Lika Electronic s.r.l.'s website. Lika Electronic s.r.l. assumes no responsibility for any errors or omissions in this document. Critical evaluation of this manual by the user is welcomed. Your comments assist us in preparation of future documentation, in order to make it as clear and complete as possible. Please send an e-mail to the following address info@lika.it for submitting your comments, suggestions and criticisms.



## **General contents**

User's	guide	1
	eral contents	
Турс	ographic and iconographic conventions	4
	iminary information	
1	Safety summary	
	1.1 Safety	
	1.2 Electrical safety	
	1.3 Mechanical safety	
2	Identification	
3	Mechanical installation	9
	3.1 Overall dimensions	9
	3.2 Sensor and ring combination	
	3.3 Mounting instructions	
	3.4 Mounting the magnetic ring	
	3.5 Mounting the sensor	
	3.6 Mounting tolerances	14
	3.7 Standard counting direction	15
4	Electrical connection	
	4.1 Cable and connector connections	
	4.2 M8 cable specifications	17
	4.3 M12 8-pin connector specifications	
	4.4 Connection of the shield	
	4.5 Ground connection	
	4.6 AB0, /AB0 output channels	
	4.7 Counting direction	
	4.8 Reference "R"	
	4.9 Diagnostic LEDs (Figure 8)	
	4.10 Recommended circuit	
5	Maintenance and troubleshooting	24

## Typographic and iconographic conventions

In this guide, to make it easier to understand and read the text the following typographic and iconographic conventions are used:

- parameters are coloured in **GREEN**;
- alarms are coloured in **RED**;
- states are coloured in FUCSIA.

When scrolling through the text some icons can be found on the side of the page: they are expressly designed to highlight the parts of the text which are of great interest and significance for the user. Sometimes they are used to warn against dangers or potential sources of danger arising from the use of the device. You are advised to follow strictly the instructions given in this guide in order to guarantee the safety of the user and ensure the performance of the device. In this guide the following symbols are used:

Â	This icon, followed by the word <b>WARNING</b> , is meant to highlight the parts of the text where information of great significance for the user can be found: user must pay the greatest attention to them! Instructions must be followed strictly in order to guarantee the safety of the user and a correct use of the device. Failure to heed a warning or comply with instructions could lead to personal injury and/or damage to the unit or other equipment.
j	This icon, followed by the word <b>NOTE</b> , is meant to highlight the parts of the text where important notes needful for a correct and reliable use of the device can be found. User must pay attention to them! Failure to comply with instructions could cause the equipment to be set wrongly: hence a faulty and improper working of the device could be the consequence.
i	This icon is meant to highlight the parts of the text where suggestions useful for making it easier to set the device and optimize performance and reliability can be found. Sometimes this symbol is followed by the word <b>EXAMPLE</b> when instructions for setting parameters are accompanied by examples to clarify the explanation.

## **Preliminary information**

This guide is designed to provide the most complete and exhaustive information the operator needs to correctly and safely install and operate the following **incremental magnetic modular encoders**: **SMRI2** and **SMRI5**.

SMRI2 and SMRI5 modular encoders are designed to measure linear or angular displacements on industrial machines and automation systems. The measurement system includes a magnetic ring, conversion electronics and a magnetic sensor.

The ring has alternating magnetic north/south poles that are magnetized at a fixed distance called the pole pitch (see Figure 7). The pole pitch is 2 mm for SMRI2; it is 5 mm for SMRI5. The conversion electronics inside the sensor translates the magnetic fields of the ring into electrical signals equivalent to those of an incremental encoder or a linear scale. The readhead must be paired with the appropriated magnetic ring: MRI/...-2-... for SMRI2; MRI/...-5-... for SMRI5; see also the "3.2 Sensor and ring combination" section on page 10.

The measuring system can include specific sensor and ring with additional magnetic track for the transmission of a Reference signal.

Please note that:

- encoders having order code SMRIx-xx-x-xxx-R-... are equipped with Reference sensor;
- rings having order code MRI/xxxZ-... have the Reference track;
- encoders having order code SMRIx-xx-x-xxx-N-... are not equipped with Reference sensor;
- rings having order code MRI/xxx-... have not the Reference track.



## 1 Safety summary



#### 1.1 Safety

- Always adhere to the professional safety and accident prevention regulations applicable to your country during device installation and operation;
- installation and maintenance operations have to be carried out by qualified personnel only, with power supply disconnected and stationary mechanical parts;
- device must be used only for the purpose appropriate to its design: use for purposes other than those for which it has been designed could result in serious personal and/or the environment damage;
- high current, voltage and moving mechanical parts can cause serious or fatal injury;
- warning ! Do not use in explosive or flammable areas;
- failure to comply with these precautions or with specific warnings elsewhere in this manual violates safety standards of design, manufacture, and intended use of the equipment;
- Lika Electronic assumes no liability for the customer's failure to comply with these requirements.



### 1.2 Electrical safety

- Turn OFF the power supply before connecting the device;
- connect according to the explanation in the "Electrical connection" section on page 16;
- the wires of unused output signals must be cut at different lengths and insulated singularly;
- in compliance with 2014/30/EU norm on electromagnetic compatibility, the following precautions must be taken:



- before handling and installing the equipment, discharge electrical charge from your body and tools which may come in touch with the device;
- power supply must be stabilized without noise; install EMC filters on device power supply if needed;
- always use shielded cables (twisted pair cables whenever possible);
- avoid cables runs longer than necessary;
- avoid running the signal cable near high voltage power cables;
- mount the device as far as possible from any capacitive or inductive noise source; shield the device from noise source if needed;
- to guarantee a correct working of the device, avoid using strong magnets on or near by the unit;

- minimize noise by connecting the cable shield (or the connector housing) and the frame to ground. Make sure that ground is not affected by noise. The connection point to ground can be situated both on the device side and on user's side. The best solution to minimize the interference must be carried out by the user;
- do not stretch the cable; do not pull or carry by cable; do not use the cable as a handle.



### 1.3 Mechanical safety

- Install the device following strictly the information in the "Mechanical installation" section on page 9;
- mechanical installation must be carried out with stationary mechanical parts;
- do not disassemble the unit;
- do not tool the unit;
- delicate electronic equipment: handle with care; do not subject the device to knocks or shocks;
- protect the unit against acid solutions or chemicals that may damage it;
- respect the environmental characteristics of the product;
- we suggest installing the unit providing protection means against waste, especially swarf as turnings, chips, or fillings; should this not be possible, please make sure that adequate cleaning measures (as for instance jets of compressed air) are in place in order to prevent the sensor and the magnetic ring from jamming.



### CAUTION

Keep magnets away from the ring, it could be damaged by strong magnetic fields.

## 2 Identification

Device can be identified through the **order code** and the **serial number** printed on the label applied to its enclosure. Information is listed in the delivery document too. Please always quote the order code and the serial number when reaching Lika Electronic for purchasing spare parts or needing assistance. For any information on the technical characteristics of the product <u>refer to the</u> <u>technical catalogue</u>.



**Warning**: encoders having order code ending with "/Sxxx" may have mechanical and electrical characteristics different from standard and be supplied with additional documentation for special connections (Technical Info).

lika

## 3 Mechanical installation




### WARNING

Installation must be carried out by qualified personnel only, with power supply disconnected and mechanical parts compulsorily in stop.

### 3.1 Overall dimensions

(values are expressed in mm)





А	Reference sensor "R" (page 21)	С	Incremental sensor
В	Diagnostic LEDs (page 22)		

### 3.2 Sensor and ring combination

The sensor has to be compulsorily paired with its specific type of magnetic ring as indicated in the table below.

Sensor	MRI ring
SMRI2-xx-x-xxx-N	MRI/xxx-xxx-2
SMRI2-xx-x-xxx-R	MRI/xxxZ-xxx-2
SMRI5-xx-x-xxx-N	MRI/xxx-xxx-5
SMRI5-xx-x-xxx-R	MRI/xxxZ-xxx-5

### 3.3 Mounting instructions

Protect the device against knocks, frictions, solvents as well as under and over temperatures. Please never stretch the cable. Do not pull or carry by cable. Do not use the cable as a handle. we suggest installing the unit providing protection means against waste, especially swarf as turnings, chips, or filings; should this not be possible, please make sure that adequate cleaning measures (as for instance jets of compressed air) are in place in order to prevent the sensor and the magnetic ring from jamming.

SMRI encoder must be compulsorily paired with MRI rings as stated in the previous section. See the order code of the rings: for example MRI/xxx-xx-**2**-xxx must be paired with SMRI2 encoder.

Make sure that the mechanical installation always complies with the system requirements for distance, planarity and parallelism between the readhead and the ring indicated in Figure 4, Figure 5 and Figure 6. Avoid any contact between the readhead and the ring.

If the Reference "R" signals are not provided (encoders having order code SMRIx-xx-x-xxx-N-... and rings having order code MRI/xxx-...) the readhead can be mounted over the ring as desired (both directions are allowed). If required, please only be careful that the sensor is properly aligned on the correct side of the ring (see Figure 5).

If the Reference "R" signals are provided (encoders having order code SMRIx-xxx-xxx- $\mathbf{R}$ -... and rings having order code MRI/xxx $\mathbf{Z}$ -...) the readhead and the ring must be compulsorily installed as shown in Figure 4. For further information please refer to the "3.5 Mounting the sensor" section on page 12.

The arrow in Figure 4 indicates the **standard counting direction** (the rising edge of A signal leads the rising edge of B signal) when the ring turns in the direction indicated by the arrow; further information in the "4.7 Counting direction" section on page 21.

### 3.4 Mounting the magnetic ring

Several types of MRI magnetic rings featuring different mechanical characteristics and mounting options are available. The rings can be fixed to the motor shaft by means of grub screws (Figure 2) or screws (Figure 3).

For technical features and dimensions of the rings please refer to the product datasheet.




Figure 2 - Mounting MRI rings with grub screws




Figure 3 - Mounting MRI rings with screws

The mark punched in the frame of the ring (see Figure 4) shows the side where the Reference track is coded. It further indicates the point when the Reference signal is transmitted. Please note that the punch mark may be provided also in the rings that do not have the Reference track.



### CAUTION

Keep magnets away from the ring, it could be damaged by strong magnetic fields.

### 3.5 Mounting the sensor




Figure 4 - Mounting the encoder / ring

Make sure that the mechanical installation complies with the system requirements concerning distance, planarity and parallelism between the sensor and the ring as indicated in the "3.6 Mounting tolerances" section on page 14. Avoid any contact between the readhead and the ring.

Fix the sensor by means of two M3 15 mm / 0.6" min. long cylinder head screws inserted in the provided holes.

The recommended tightening torque is  $\ensuremath{\textbf{1.1}}\xspace$  Nm.

The recommended **minimum bend radius** of the cable is:  $R \ge 42 \text{ mm}$ .

Install the sensor and the magnetic ring as shown in the Figure. As previously stated, the arrow is intended to indicate the standard counting direction (the rising edge of A signal leads the rising edge of B signal).

The distance D (see Figure 4) between the bottom of the readhead and the MRI magnetic ring must be as follows:

Comeon	Distance D between sensor / ring		
Sensor	without Reference	with Reference	
SMRI2	0.1 mm ÷ 1.0 mm 0.004" ÷ 0.039"	0.1 mm ÷ 0.7 mm 0.004" ÷ 0.027"	
SMRI5	0.1 mm ÷ 2.0 mm 0.004" ÷ 0.078"	0.1 mm ÷ 1.5 mm 0.004" ÷ 0.059"	

### For better operation we suggest the following distance D:

Sensor	Recommended distance D between sensor and ring
SMRI2	0.5 mm / 0.019"
SMRI5	1.0 mm / 0.039"



### WARNING


When the "R" Reference signal is available (encoders having order code SMRIxxx-x-xxx- $\mathbf{R}$ -... and rings having order code MRI/xxx $\mathbf{Z}$ -...) please pay attention to the mounting side of the magnetic ring: there is the incremental track on one side and the Reference track on the other side. The mark punched in the frame of the ring shows the side where the Reference track is coded. It further indicates the point when the Reference signal is transmitted. See Figure 4.



### WARNING

When the sensor is installed on magnetic rings having a 10 mm / 0.4" wide magnetic surface, line up both the sensor and the ring on the central axis; as previously stated, if the Reference track is provided pay attention to the mounting direction of the sensor and the ring.

When magnetic rings having a 5 mm / 0.2" wide magnetic surface are used, line up the sensor and the ring as shown in Figure 5; please consider that the incremental sensor is located laterally in the sensing head (see Figure 1). With 5 mm rings the mounting direction of the ring makes no difference (but be sure that the sensor is properly aligned on the correct side!).



#### 3.6 Mounting tolerances

Always comply with the mounting tolerances indicated in Figure 4, Figure 5 and Figure 6. Make sure that the mechanical installation complies with the system requirements concerning distance, planarity and parallelism between the sensor and the ring.




Figure 6 - Mounting tolerances of the readhead / ring

### 3.7 Standard counting direction

The positive counting direction (the rising edge of A signal leads the rising edge of B signal) is achieved when the ring turns according to the arrow shown in Figure 4. For further information see the "4.7 Counting direction" section on page 21.

# lika

## 4 Electrical connection



### WARNING

Electrical connection must be carried out by qualified personnel only, with power supply disconnected and mechanical parts compulsorily in stop.



### WARNING

If wires of unused signals come in contact, irreparable damage could be caused to the device. Thus they must be cut at different lengths and insulated singularly.

Function	M8 cable	M12 8-pin
0Vdc	Black	1
+Vdc <sup>1</sup>	Red	2
А	Yellow	3
/A	Blue	4
В	Green	5
/B	Orange	6
0 <sup>2</sup>	White	7
/0 <sup>2</sup>	Grey	8
Shield	Shield	Case

### 4.1 Cable and connector connections

1 See the order code for power supply voltage level



### EXAMPLE

SMRI2-L-1-...  $+Vdc = +5Vdc \pm 5\%$ SMRI5-YC-2-... +Vdc = +10Vdc + 30Vdc

2 Reference signals (see the "4.8 Reference "R"" section on page 21) are only available with encoders having order code SMRIx-xx-x-xxx-R-... and rings having order code MRI/xxxZ-... With encoders having order code SMRIx-xxx-xxx-N-... and rings having order code MRI/xxx-... the signals are not provided.



 $\mathbf{i}$ 

### NOTE

All sensors can provide inverted signals. A = A signal;

|A = inverted A signal (or complementary signal).


All Lika's magnetic encoders can provide ABO, /ABO output signals. You are advised to always connect the inverted signals if the receiving device will accept them. Otherwise each output should be insulated singularly.

### 4.2 M8 cable specifications

Model:	LIKA HI-FLEX sensor cable type M8
Cross section:	2 x 0.22 mm <sup>2</sup> + 6 x 0.14 mm <sup>2</sup> (24/26 AWG)
Jacket:	Matt Polyurethane (TPU) halogen free, oil, hydrolysis,
	abrasion resistant
Shield:	Tinned copper braid, coverage > 85%
Outer diameter:	5.3 ÷ 5.6 mm (0.209" ÷ 0.220")
Min. bending radius:	outer diameter x 7.5
Work temperature :	dynamic -40°C +90°C (-40°F +194°F) / fixed -50°C
	+90°C (-58°F +194°F)
Conductor resistance:	<90 $\Omega/{ m Km}$ (0.22 mm²), <148 $\Omega/{ m Km}$ (0.14 mm²)

The total length of the cable that connects the sensor and the receiving device should not exceed the values stated in the "Cable lengths" section of the rotary encoders' catalogue; they are specific for each type of output circuit. If you need to reach greater distances please contact Lika Electronic Technical Dept. Do not bend the cable excessively; the min. bending radius is  $\emptyset \times 7.5$  at a minimum distance of 10 mm from the sensor head.


### 4.3 M12 8-pin connector specifications



Male Frontal side A coding


### 4.4 Connection of the shield

For signals transmission always use shielded cables. The cable shielding must be connected properly to the metal ring nut **3** of the connector in order to ensure a good earthing through the frame of the device. To do this disentangle and shorten the shielding **1** and then bend it over the part **2**; finally place the ring nut **3** of the connector. Be sure that the shielding **1** is in tight contact with the ring nut **3**.



### 4.5 Ground connection

Minimize noise by connecting the cable shield (or the connector housing) and the sensor to ground. Make sure that ground is not affected by noise. The connection point to ground can be situated both on the device side and on the user's side. The best solution to minimize the interference must be carried out by the user. You are advised to provide the ground connection as close as possible to the encoder.



## lika

### 4.6 ABO, /ABO output channels




Figure 7 - Example with interpolation factor x4

The conversion electronics inside the sensor translates the magnetic fields of the ring into electrical signals equivalent to those of an incremental encoder or similar incremental optical devices.

The frequency of the output signal is proportional to the measuring speed and the rotational speed of the ring.

Please note that the "R" Reference signal (0, /0) is provided once per revolution of the magnetic ring (see the "4.8 Reference "R"" section on page 21).

In the order code of the encoder you can find information about the interpolation factor.



### EXAMPLE

SMRI2-L-1-1000-N-...: interpolation factor = 1000.

The interpolation factor is useful to calculate the number of encoder PPRs (pulses per revolution).

You need to know also the number of poles of the magnetic ring, the information can be found in the order code of the magnetic ring.



### EXAMPLE

MRI/114-**182**-2-100: number of poles = 182.

The number of encoder PPRs results from the following calculation:

interpolation factor \* number of ring poles



### EXAMPLE

As in the previous examples, let's suppose we are using the SMRI2-L-1-**1000**-N-... encoder paired with the MRI/114-**182**-2-100 magnetic ring where 182 is the number of ring poles. As you can see in the order code, the interpolation factor is x1000. We have to calculate the number of edges per revolution (intended after multiplying by 4) first.

The number of edges per revolution results from:

interpolation factor \* number of ring poles

So, in our example we will get:

1000 \* 182 = 182,000 edges per revolution

Encoder PPRs result from the following calculation:

Encoder PPRs =  $\frac{\text{Edges/revolution}}{4} = \frac{182,000}{4} = 45,500 \text{ PPR}$ 



### WARNING

The position value issued by the sensor is expressed in pulses; to convert the pulses into a metric measuring unit (useful, for instance, for knowing the position of a linear axis controlled through the encoder) you must multiply the number of detected pulses by the linear resolution expressed in millimetres or micrometres.

We know the interpolation factor of the encoder, so we can calculate the linear resolution expressed in millimetres or micrometres. It results from the following formula:

pitch of the ring pole / interpolation factor

The pole pitch is 2 mm for SMRI2 + MRI/...-2-...; it is 5 mm for SMRI5 + MRI/...-5-... .

In our example it will be as follows:

2 / 1000=0.002 mm = 2  $\mu m$ 



EXAMPLE

SMRI2-L-1-**1000**-N-... encoder MRI/114-**182**-2-100 magnetic ring resolution = 2  $\mu$ m = 0.002 mm detected pulses = 2,866 position value = 2,866 \* 2 = 5,732  $\mu$ m = 5.732 mm

### 4.7 Counting direction

The phase relationship between A and B channels is so that the rising edge of A channel leads the rising edge of B channel when the ring turns in the direction shown by the arrow in Figure 4. See also the previous "4.6 ABO, /ABO output channels" section on page 19. Thus the counter in the subsequent electronics will get a count up. The counting direction cannot be changed.

### 4.8 Reference "R"

Reference signals (0, /0) are available in the encoders having order code SMRIxxx-x-xxx- $\mathbf{R}$ -... and rings having order code MRI/xxx $\mathbf{Z}$ -... . In the encoders having order code SMRIx-xx-x-xxx- $\mathbf{N}$ -... and rings having order code MRI/xxx-... the Reference signals are not available.

They provide a univocal position information once per revolution of the magnetic ring for use at power-on or following a loss of power. In the measuring systems equipped with Reference sensor the "R" LED (see the "4.9 Diagnostic LEDs (Figure 8)" section) lights up when the Reference South pole is detected. Please note that this does not mean that the Reference pulse is output in the same time: the Reference pulse is synchronized with A and B channels within the South pole and has a duration of one measuring step (90 electrical

degrees  $\pm$  30°). Thus, it may be either not output yet or already output while the LED is lit. The Reference signal has an amplitude according to the power supply voltage level.



### NOTE

The Reference track can be available only in the magnetic rings having a 10 mm / 0.4" wide magnetic surface. Magnetic rings having a 5 mm / 0.2" wide magnetic surface cannot have the Reference track.

### 4.9 Diagnostic LEDs (Figure 8)

Two LEDs located in the upper face of the encoder enclosure are intended to show visually the work status of the device as explained in the following table.





Figure 8 - Diagnostic LEDs and optional cleaning wipers


E RED LED (error status)	Description
ON <mark>Red</mark>	<ul> <li>It warns of the presence of an error.</li> <li>Distance error: the specified mounting tolerances between the sensor and the ring are not met; please refer to the "Mechanical installation" section on page 9.</li> <li>Speed / frequency error: overspeed detected, the rotational speed of the ring is too high.</li> </ul>
OFF	No error is active currently.

R GREEN LED (Reference)	Description
ON Green	<ul> <li>Sensors with Reference ("-R-" order code): Reference south pole detected, zero signal. It is on as long as the Reference South pole is detected. Refer to the "4.8 Reference "R"" section on page 21.</li> <li>Sensors without Reference ("-N-" order</li> </ul>


	code): the encoder is supplied.
OFF	<ul> <li>Sensors with Reference ("-R-" order code): no Reference signal.</li> <li>Sensors without Reference ("-N-" order code): the encoder is not supplied.</li> </ul>

### 4.10 Recommended circuit






### Push-Pull (YC order code)



### Line Driver (L order code)



## 5 Maintenance and troubleshooting

The magnetic measurement system does not need any particular maintenance; please always consider it is a delicate electronic equipment and therefore it must be handled with care. From time to time we recommend the following operations:

- Check the mounting tolerances between the sensor and the magnetic ring are always met. Wear of the machine may increase the tolerances.
- The surface of the magnetic ring should be cleaned periodically using a soft cloth to remove dust, chips, moisture etc.

The following list shows some typical faults and errors that may occur during installation and operation of the magnetic measurement system. Refer also to the "4.9 Diagnostic LEDs (Figure 8)" section on page 22.

### Fault:

The system does not work (no pulse output).

### Possible cause:

- The ring or the sensor has been mounted incorrectly.
- A magnetic piece or an inappropriate strip is in between the sensor and the ring. Only non-magnetic materials are allowed between the sensor and the ring.
- The sensor touches the ring: the mounting tolerances are not met. Check if the active side of the sensor is damaged.
- The sensor has been damaged by a short circuit or a wrong connection.

### Fault:

The measured values are inaccurate.

### Possible cause:

- The mounting tolerances between the sensor and the ring are not always met.
- The connection cable runs near to high voltage cable or shield is not connected correctly. See the "4 -Electrical connection" section on page 16.
- The presence of external noise may cause malfunctioning or a decrease in the quality of the signals.
- The max. counting frequency of your receiving device is too low.
- A section of the magnetic ring has been damaged mechanically or magnetically.

٠

The measuring error is caused by torsion of the machine structure. Check parallelism and symmetry of machine movement. This page intentionally left blank

This page intentionally left blank

Document release	Release date	Description	HW	SW	Interface
1.0	07.08.2013	First issue	-	-	-
1.1	07.11.2013	New web links	-	-	-
1.2	30.07.2014	Information about Reference	-	-	-
1.3	12.09.2014	Mounting instructions updated, general review	-	-	-
1.4	20.12.2018	General review, SMRI2/SMRI5 manuals merged, separate Italian and English versions	-	-	-
1.5	23.07.2019	Information about Reference signals and operation of the Reference LED updated	_	_	-







Lika Electronic Via S. Lorenzo, 25 • 36010 Carrè (VI) • Italy

> Tel. +39 0445 806600 Fax +39 0445 806699



info@lika.biz • www.lika.biz

